


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 01/03/2024

It is certified that an inspection team headed by Sarjan Patarya, Chemist A/Range(Name of Officers with designation) from Chemist Lab A/Range(Name of Department/ Office) inspected the P.H.E. Department A/Range(Name & Address of the school) on 26/02/2024 (date of inspection) and found that the Sanskriti-An Eng. Med. School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.The above is valid for a period of 2024-25

Signature with Seal: लोक स्वास्थ्य यांत्रिकीय विभाग
उपखण्ड अशोकनगर (म.प्र.)Name : B.S. SeemanDesignation : Assistant EngineerName & Address of the Office / Department : P.H.E A/Range

To

Sanskriti-An English Medium SchoolAshoknagar (M.P.)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

DISTRICT WATER TESTING LABORATORY,

Public Health Engineering Department (PHED) Store,
Pathar Mohalla, District Ashoknagar (M.P.)

Test Report

Nature Of Sample	Drinking water sample	Not Sampled by Division Water testing Lab. Ashoknagar	Unique Identification No.
Sender's Name & Address Samskruti an english medium School ASHOK NAGAR		Sender's Letter No.	
		Sender's Letter date. 26/02/2024	
		DWTL Letter Receipt No.	
		DWTL Letter Receipt Date. 26/02/2024	
		Date of Analysis started 26/02/2024	
		Date of Analysis Completed 27/02/2024	
		Quantity of Sample . 1 liter. ok	

Sample Details :

S.No	Block	Gram Panchayat	Village	Location	Source
1					
2					

Physical & Chemical Test Report With Details Of Parameters Their Test Methods , Units And Specification as per BIS.

S.No	Characteristics	Unit	As Per BIS 10500:2012 & Reaffirmed in sep . 2018		Test Result	
			Requirement (Desirable Limit)	Permissible Limit in the absence of alternate Source	Sample Numbers	
					1	2
PHYSICAL TEST						
1	Temperature	C	-	-	-	
2	Turbidity	NTU	1	5	1.2	
3	Colour	Hazen Unite	5	15	6	
4	Test and odour	-	Unobjectionable	Unobjectionable	Unobj-	
CHEMICAL TEST						
5	pH Value	pH Scale	6.5 -8.5	No relaxation	7.4	
6	Total Alkalinity (asCaCO3)	mg/l	200	600	120	
7	Chlorides	mg/l	250	1000	210	
8	Nitrates	mg/l	45	45	2	
9	Total Hardness(as CaCO3)	mg/l	200	600	225	
10	Calcium (as Ca)	mg/l	75	200	48	
11	Magnesium(as Mg)	mg/l	30	100	28.8	
12	Total Dissolved Solids (T.D.S.)	mg/l	500	2000	290	
13	Fluoride	mg/l	1	1.5	0.2	
14	Iron	mg/l	0.3	1	0.1	
15	Arsenic	mg/l	0.01	0.01	0	
16	Total Coliform	Per 100ml	0	0	0	
17	E-coli	Per 100ml	0	0	0	
18	Manganese	mg/l	0.01	0.03	-	
19	Sulphate	mg/l	200	400	-	
20	Residul Chlorine	mg/l	0.2	1	-	

Remark:- According to the test Water of given Sample is Fit / Unfit for drinking Purpose.


CHEMIST
 District Water Testing Laboratory
 PHED Division Ashoknagar (M.P.)
PHE DASHOKNAGAR (M.P.)

Issue / Dispatch No. / DWTL/PHED/Ashok Nagar/2023


ASSISTANT ENGINEER
 Public Health Engineering Department
 PHED Division Ashoknagar (M.P.)
PUBLIC HEALTH ENGINEER DEPARTMENT
SUB-DIVISION ASHOKNAGAR (M.P.)

Issue / Dispatch Date